

C € 0085



CERT

EU type examination certificate
EU-Baumusterprüfbescheinigung

CE-0085BS0516

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Wolf GmbH Industriestraße 1, D-84048 Mainburg
Distributor <i>Vertreiber</i>	Wolf GmbH Industriestraße 1, D-84048 Mainburg
Product Category <i>Produktart</i>	Boilers: Water heater for central heating (3101)
Product Description <i>Produktbezeichnung</i>	water heater for central heating optionally as combi water heater
Model <i>Modell</i>	CGU-2...
Countries of Destination <i>Bestimmungsländer</i>	AT, BE, BG, BY, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MD, MT, NL, PL, PT, RO, RU, SE, SI, SK, TR, UA
Test Reports <i>Prüfberichte</i>	supplement test: 149495cE8/18128 from 28.10.2021 (GWI)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-2 (01.10.2014) DVGW CERT ZP 3100 (07.10.2020)
Date of Expiry / File No. <i>Ablaufdatum / AZ</i>	31.01.2028 / 21-0735-GEA

70028-04-A-DE

18.01.2022 Kö A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data 230 V AC, 50 Hz, P = 83 VA, IPX4D
Elektrische Daten

Appliance Categories <i>Gerätekategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2Er	20/25 mbar	BE, FR	
I2H	20 mbar	IT	
I3P	37 mbar	BE, CY, FR, MT	
II2E Lw3P	20, 37 mbar	PL	
II2E3P	20, 50 mbar	LU	
II2ELL3P	20, 50 mbar	DE	
II2H3P	20, 37 mbar	CZ, DK, EE, ES, FI, GB, GR, IS, IT, LT, LV, PT, SE, SI, SK, TR	
II2H3P	20, 50 mbar	AT, CH, CZ, ES, FI, GB, GR, HU, IE, IS, PT, SE, TR	
II2H3P	25, 30 mbar	HU	
II2L3P	25, 30 mbar	NL	
II2L3P	25, 50 mbar	NL	

Installation Codes <i>Installationsarten</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
B11BS	AT, BE, BG, BY, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MD, MT, NL, PL, PT, RO, RU, SE, SI, SK, TR, UA	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
CGU-2-10	nominal heat output: 7,5...10,0 kW heat input (Hi): 8,3...11,2 kW	
CGU-2K-18	nominal heat output: 8,0...18,0 kW heat input (Hi): 8,8...20,2 kW	
CGU-2K-24	nominal heat output: 10,9...24,0 kW heat input (Hi): 12,0...26,5 kW	
CGU-2K-18T	nominal heat output: 8,0...18,0 kW heat input (Hi): 8,8...20,2 kW	
CGU-2K-24T	nominal heat output: 10,9...24,0 kW heat input (Hi): 12,0...26,5 kW	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
CGU-2-...	water heater for central heating
CGU-2K-...	combi water heater
...T	appliance with variable exhaust temperature increase

Hints of Utilization /Remarks
Verwendungshinweise / Bemerkungen

Additionally tested appliance categories, supply pressures and countries of destination:

MD: II2H3P (20, 30 mbar)

BG, BY, HR, MD, RU, UA: II2H3P (20, 37 mbar)

BG, BY, HR, RU, UA: II2H3P (20, 50 mbar)

In the non-EU countries the conformity approval will be accepted if the Gas Appliance Regulation EU/2016/426 is transferred into national law by this countries.

The recognition of the CE mark in the United Kingdom is currently limited to Januar 1st, 2023.

The boilers are qualified for the addition of up to 20 vol.-% hydrogen to natural gas (G20) as burning gas according to DVGW CERT ZP 3100.

